

MONTH WISE MAXIMUM DEMAND OF POWER AT THE RESPECTIVE REGIONAL SUB-STATIONS

MD In MW

Sl. No	Month	230 KV Villianur SS	230 KV Thoanda manatham SS	230 KV Bahour SS	Total MD of 230 KV SS	TNEB power drawn at Pandy	Total for Pandy	MD of power drawn at Karaikal		Total for Karaikal	Mahe	Yanam 132 KV SS	Total for UT
					(3+4+5)		(5+6)	Sorakudy	PPCL	(8+9)			(7+10+13+14)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)	(14)
1.	04/15	112.70	137.00	97.70	347.40	0.00	347.40	62.01	32.00	94.01	7.00	10.25	458.66
2.	05/15	127.00	136.00	93.50	356.50	0.00	356.50	56.38	32.00	88.38	6.76	10.50	462.14
3.	06/15	132.90	127.00	99.90	359.80	0.00	359.80	41.24	32.00	73.24	6.78	10.90	450.72
4.	07/15	127.70	133.30	93.50	354.50	0.00	354.50	40.92	32.00	72.92	6.54	16.20	450.16
5.	08/15	123.80	130.80	94.90	349.50	12.19	361.69	38.99	32.00	70.99	6.38	11.80	450.86
6.	09/15	134.70	128.60	112.40	375.70	0.00	375.70	50.96	32.00	82.96	6.61	10.40	475.67
7.	10/15	123.20	136.90	94.90	355.00	0.00	355.00	43.95	32.00	75.95	6.62	10.50	448.07
8.	11/15	107.40	123.00	96.60	327.00	0.00	327.00	29.83	32.00	61.83	7.08	9.70	405.61
9.	12/15	107.40	125.00	90.10	322.50	0.00	322.50	21.61	32.00	53.61	6.80	9.10	392.01
10.	01/16	107.70	126.10	86.50	320.30	0.00	320.30	39.48	32.00	71.48	6.60	9.00	407.38
11.	02/16	115.00	125.00	92.30	332.30	0.00	332.30	32.53	32.00	64.53	6.64	9.05	412.52
12.	03/16	123.20	136.90	94.90	355.00	8.42	363.42	35.63	32.00	67.63	7.58	8.90	447.53
Maximum Demand		134.70	137.00	112.40	375.70	12.19	375.70	62.01	32.00	94.01	7.58	16.20	475.67

MONTH WISE MAXIMUM DEMND OF POWER AT THE RESPECTIVE REGIONAL SUB STATIONS

MD in MW

Sl.No	Month	230 KV Villianur SS	230 KV Bahour SS	230 kv Thoanda manatha m SS	Total MD of 230 KV SS	TNEB power drwan at Pondy	Total for Pondy	MD of power drwan at Karaikal		Total for Karaikal	Mahe	Yanam 132 KV SS	Total for U.T
								Sorakudy	PPCL				
1	2	3	4	5	6=(2+3+4)	7	8=6+7	9	10	11=9+10	12	13	14=8+11+12+13
1	Apr-16	131.30	98.40	137.30	367.00	0.00	367.00	42.94	32.00	74.94	7.32	10.20	459.46
2	May-16	165.40	99.80	137.70	402.90	0.00	402.90	39.71	32.00	71.71	7.33	10.30	492.24
3	Jun-16	134.00	121.60	144.50	400.10	0.00	400.10	37.73	32.00	69.73	7.42	10.80	488.05
4	Jul-16	133.00	108.23	109.21	350.44	0.00	350.44	37.56	32.00	69.56	6.47	9.75	436.22
5	Aug-16	131.70	99.80	135.20	366.70	0.00	366.70	51.25	32.00	83.25	6.64	9.50	466.09
6	Sep-16	148.80	97.70	130.00	376.50	0.00	376.50	46.41	32.00	78.41	6.61	10.02	471.54
7	Oct-16	151.50	105.50	125.90	382.90	0.00	382.90	56.10	32.00	88.10	6.65	10.00	487.65
8	Nov-16	143.10	106.80	124.70	374.60	0.00	374.60	47.29	32.00	79.29	6.58	9.10	469.57
9	Dec-16	143.10	106.80	124.70	374.60	0.00	374.60	21.42	32.00	53.42	6.21	9.50	443.73
10	Jan-17	134.00	95.60	121.30	350.90	0.00	350.90	25.49	32.00	57.49	6.65	10.00	425.04
11	Feb-17	139.40	99.80	104.00	343.20	0.00	343.20	22.22	32.00	54.22	7.07	10.95	415.44
12	Mar-17	145.50	104.00	110.60	360.10	0.00	360.10	35.39	32.00	67.39	6.72	11.98	446.19
Maximum Demand		165.40	121.60	144.50	402.90	0.00	402.90	56.10	32.00	88.10	7.42	11.98	492.24

MONTH WISE MAXIMUM DEMND OF POWER AT THE RESPECTIVE REGIONAL SUB STATIONS

MD in MW

Sl.No	Month	230 KV Villianur SS	230 KV Bahour SS	230 KV Thoanda manatha m SS	Total MD of 230 KV SS	TNEB power drwan at Pondy	Total for Pondy	MD of power drwan at Karaikal		Total for Karaikal	Mahe	Yanam 132 KV SS	Total for U.T
								Sorakudy	PPCL				
1	2	3	4	5	6=(2+3+4)	7	8=6+7	9	10	11=9+10	12	13	14=8+11+12+13
1	Apr-17	165.00	104.00	112.30	381.30	0.00	381.30	52.24	32.00	84.24	7.30	10.91	483.74
2	May-17	178.10	115.00	128.30	421.40	0.00	421.40	43.92	32.00	75.92	7.73	10.45	515.50
3	Jun-17	173.40	117.60	117.50	408.50	0.00	408.50	40.65	32.00	72.65	7.00	10.86	499.01
4	Jul-17	181.00	121.40	120.80	423.20	0.00	423.20	46.04	32.00	78.04	6.95	10.00	518.19
5	Aug-17	171.60	120.70	121.00	190.50	0.00	190.50	49.48	32.00	81.48	6.95	9.50	288.43
6	Sep-17	190.50	123.50	119.80	433.80	0.00	433.80	36.38	32.00	68.38	6.93	10.12	519.23
7	Oct-17	156.50	106.40	112.00	374.90	0.00	374.90	33.14	32.00	65.14	6.59	10.00	456.63
8	Nov-17	151.30	95.60	124.70	105.00	0.00	105.00	24.18	32.00	56.18	7.13	9.10	177.41
9	Dec-17	155.80	96.30	107.00	359.10	0.00	359.10	25.19	32.00	57.19	7.50	9.50	433.29
10	Jan-18	143.80	111.00	106.70	361.50	0.00	361.50	40.45	32.00	72.45	6.88	10.52	451.35
11	Feb-18	160.10	99.80	111.30	371.20	0.00	371.20	39.16	32.00	71.16	7.07	10.95	460.37
12	Mar-18	145.50	104.00	110.60	360.10	0.00	360.10	35.81	32.00	67.81	6.72	11.85	446.48
Maximum Demand		190.50	123.50	128.30	433.80	0.00	433.80	52.24	32.00	84.24	7.73	11.85	519.23