



Government of India
Central Electricity Authority
Regional Inspectorial Organisation (South)
Block IV, Floor III, Shastri Bhawan, Chennai – 600 006



Telefax:
044-28237051

Phone:
044-28276579

e-mail:
riosouthceachennai@gmail.com

No. 78/P-193/1/2017/RIO - S/ 1617

Dated: 07.02.2017

To

The Authorised Dignitary
M/s National Plastics Technologies Ltd
No. 127, Thiruvandar Koil
Mannadipet Commune
Puducherry – 605 102.

Approval for Energizing Electrical Installations
(Under Regulation 43)

Installation:-

Equipment:	i) 22 kV DP structure ii) Transformer 800 kVA, 22/ 0.433 kV, Make: Supreme. SI. No.:SPEL/7444 iii) Associated cables, panels and motors
Location:	National Plastics Technologies Ltd, Pudussery
Inspected by:	Deputy Director, RIO, CEA, Chennai on 20.01.2017.

Reference:-

Your Letter No.	On-line application no. A/2017/01629	Dated	29.11.2016
Our Letter No. (Inspection Report)	78/P-193/1/2017/RIO - S/1599	Dated	03.02.2017
Your Letter No. (Compliance)	56/2/17 dated	Dated	06.02.2017

With reference to the above, approval is hereby granted for energizing the electrical installation as given above. This approval is strictly subject to your full compliance with the relevant provisions of the CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended to date) in every respect. The statement of energisation may please be forwarded to this office immediately after energisation of the installation.

The next inspection of these equipment under regulation 30 shall be due after two years from the date of this approval.


(Gopinadhan Pillai)
Deputy Director
for CEI to Govt. of India

Copy to: - The Chief Engineer (CEI), CEA, New Delhi – 110 066

गोपिनाथन पिल्लै / GOPINADHAN PILLAI
उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्ने / Chennai-600 006