

No. 3891/ED/SE-O&M-Pdy/Tech-III/F.HT/2017-18  
GOVERNMENT OF PUDUCHERRY  
ELECTRICITY DEPARTMENT

Puducherry,  
dt.19.01.2018

JERC / Ph  
Scan  
An  
18/18

**MEMORANDUM**

Sub : Electricity Department, Puducherry - SE-O&M-Pdy - Tech-III - Enhancement of CMD from 600 KVA to 1200 KVA in favour of M/s. Poclain Hydraulics Pvt. Ltd., R.S. No.131/2, Kothapurinatham Road, Thiruvandar Koil Village, Mannadipet Commune, Puducherry- Approval accorded - Reg.

Ref : 1. Licence No.34-417/MCP/Lic/2008 dt.28.10.2008  
Order No.34-417/MCP/LIC/2017 dt.10.05.2017  
2. SE-III Order No.HT - 10/2017-18 dt.23.11.2017  
3. No.78/P-370/5/2017-RIO/329 dt.12.06.2017  
4. I.D. No.3537/ED/EE-R(S)/Tech/F.HT /2017-18 dt.26.12.2017

-oOo-

Approval of the Superintending Engineer-cum-HoD is hereby communicated for enhancement of CMD from 600 KVA to 1200 KVA in favour of M/s. Poclain Hydraulics Pvt. Ltd., R.S. No.131/2, Kothapurinatham Road, Thiruvandar Koil Village, Mannadipet Commune, Puducherry on **19.01.2018** with a total connected load of 1646.42KW, including light load, subject to the following conditions:-

- a) Provisions of JERC (Electricity Supply Code) Regulations, 2010 dated 20.05.2010 should be strictly adhered to.
- b) The sanctioned Maximum Demand of 1200 KVA should not be exceeded at any time.
- c) The capacity of the Current Transformer of the Controlling feeder and Station Capacity and for the metering at the consumer end should be adequate.

(Contd.....)



- d) The consumer will be continued to be charged under the tariff HT-I (a).
- e) The initial reading of the meter and metering particulars should be forwarded to Tech-I Sub Division and SAO/HT with a copy to this office.

*T. Gopalakrishnan*  
19.01.14

(T. Gopalakrishnan)  
Superintending Engineer-O&M  
Puducherry Region

To

The Executive Engineer-Rural (South) O&M, -- (2 copies)  
Electricity Department,  
Puducherry.

Copy to:

1. The Superintending Engineer - cum- HoD - For information
2. The Executive Engineer - MRT & MMC (2 copies) - For information and necessary action
3. The Senior Account Officer/HT Section - For information
4. Assistant Engineer/Computer - For information
5. The spare

GOVERNMENT OF PUDUCHERRY  
ELECTRICITY DEPARTMENT