

No. 4033/ED/SE-O&M-Pdy/Tech-III/F.HT/2017-18  
GOVERNMENT OF PUDUCHERRY  
ELECTRICITY DEPARTMENT

Puducherry,  
Dt. 24.01.2018

**MEMORANDUM**

Sub : Electricity Department, Puducherry - SE-O&M-Pdy - Tech-III - Extension of 11 KV H.T power supply for a CMD of 300 KVA in favour of Thiru R. Rathinavelu Ramesh at R.S. No. 336/7 & 8, Door No. Old. 14, New No. 96, Kamaraj Salai, Puducherry - Approval Accorded - Reg.

Ref : 1. Licence No.1/2017-18 dt.5-4-2017 ( Trade licence in the Name of M/s. Kalyan Jewellers India Ltd.) from the Oulgaret Municipality.  
2. G.O. No. 11011/6/ID(P)D/P2/2017-18 dt.22-08-2017.  
3. No.78/P-590/10/2017-RIO/955 dt.01.11.2017  
4. I.D. No.8082/ED/EE-UR/JE/F.26(Rathana)/17-18 dt.10.01.2018.


-oOo-

Approval of the Superintending Engineer-cum-HoD is hereby communicated for extension of 11 KV H.T power supply for a CMD of 300 KVA in favour of Thiru R. Rathinavelu Ramesh at R.S. No. 336/7 & 8, Door No. Old. 14, New No. 96, Kamaraj Salai, Puducherry on **24.01.2018** with a total connected load of 179.83 KW, including light load, subject to the following conditions:-

- a) Provisions of JERC (Electricity Supply Code) Regulations, 2010 dated 20.05.2010 and the amendment notified vide The Gazette of India No. 224 dt.07.08.2013 should be strictly adhered to.
- b) The sanctioned Maximum Demand of 300 KVA should not be exceeded at any time.
- c) The capacity of the Current Transformer of the Controlling feeder and Station Capacity should be adequate.
- d) Approval for installing & running Gen set as stand by source shall be obtained from this Department, separately by applying to the Executive Engineer O&M (concerned), after energisation.



- e) As stipulated in the Office Memorandum No.4032/ED/SE-I/F.49/2011-12 dt.19.03.12, the maximum available C.T ratio of metering cubicle shall be adopted.
- f) The consumer will be charged under the tariff HT-I (b).
- g) The initial reading of the meter and metering particulars should be forwarded to Tech-I Sub Division and SAO/HT with a copy to this office.
- h) The compliance on the obligations of the Renewable Energy requirement by the consumer, within the time line shall be ensured.

  
7/9  
Superintending Engineer-O&M  
Puducherry Region

To

The Executive Engineer-Urban O&M, (2 copies),  
Electricity Department,  
Puducherry.

Copy to:

1. The Superintending Engineer - cum- HoD - For information.
  2. The Executive Engineer MRT & MMC (2 copies) - For information and necessary action.
  3. The Senior Account Officer/HT Section - For information
  4. The Assistant Engineer / Computer - For information
- w.r.to No.1894/ED/SE-I/Tech-I/F.10/EODB/2017-18 dt.13.09.17
5. The spare.