

Puducherry,
dt.06.02.2018

MEMORANDUM

Sub : Electricity Department, Puducherry - SE-O&M-Pdy - Tech-III - Enhancement of CMD from 410 KVA to 900 KVA in favour of M/s. Venkataramana Food Specialities Ltd., MSI Area, 24th Cross, PIPDIC Industrial Estate, Mettupalyam, Oulgaret Municipality, Puducherry- Approval accorded - Reg.

Ref : 1. Licence No.1174/Lic-121/OCP/92 dt.27.11.1992
Permission No.F.No.42-2011/LIC/OM/2014 dt.01.08.2014
2. SE-III Order No.HT - 10/2016-17 dt.17.08.2016
3. No.78/P-585/8/2017-RIO/744 dt.12.09.2017
4. I.D. No.5325/ED/EE-R(N)/Tech/F.HT (Venkat 410-900KVA)/17-18 dt.22.12.2017


-oOo-

Approval of the Superintending Engineer-cum-HoD is hereby communicated for enhancement of CMD from 410 KVA to 900 KVA in favour of M/s. Venkataramana Food Specialities Ltd., MSI Area, 24th Cross, PIPDIC Industrial Estate, Mettupalyam, Oulgaret Municipality, Puducherry on **06.02.2018** with a permitted connected load of 722.87KW (969HP), including light load, subject to the following conditions:-

- a) Provisions of JERC (Electricity Supply Code) Regulations, 2010 dated 20.05.2010 should be strictly adhered to.
- b) The sanctioned Maximum Demand of 900 KVA should not be exceeded at any time.
- c) The capacity of the Current Transformer of the Controlling feeder and Station Capacity and for the metering at the consumer end should be adequate.
- d) The enhancement of permitted connected load from 722.87KW to 1390.11KW within the sanctioned CMD shall be allowed subject to production of Municipality Permission / Licence for the enhanced connected load in accordance with Clause 4.1 (d) of Procedure and Guidelines for HT service connection 2010.

..2/-

- e) Municipality Permission / Licence for a permitted connected load of 1390.11KW shall be furnished within two months, from the date of enhancement of CMD.
- f) Department approval should be obtained for 1010KVA DG set within fifteen days from the date of energisation.
- g) The consumer will be continued to be charged under the tariff HT-I (a).
- h) The initial reading of the meter and metering particulars should be forwarded to Tech-I Sub Division and SAO/HT with a copy to this office.
- i) Compliance of the Renewable Energy requirement as per the Puducherry Building Bye-Laws and Zoning Regulations (Amendment), 2017 as per the Notification of the Chief Secretariat (Housing) vide G.O.Ms.No.12/2017-Hg, Puducherry dt. 13.07.2017, within a time frame shall be ensured.

7/9

 (T. Gopalakrishnan)
 Superintending Engineer-O&M
 Puducherry Region

To

The Executive Engineer-Rural (North) O&M -- (2 copies),
 Electricity Department,
 Puducherry.

Copy to:

- | | |
|--|--|
| 1. The Superintending Engineer - cum- HoD | - For information |
| 2. The Executive Engineer - MRT & MMC (2 copies) | - For information and necessary action |
| 3. The Senior Account Officer/HT Section | - For information |
| 4. Assistant Engineer/Computer | - For information alongwith copy of CEA approval |
| 5. The spare | |